



BLIS.R26079 Caulking and Sealants

[Page Bottom](#)

Caulking and Sealants

[See General Information for Caulking and Sealants](#)

NAPCO MIDDLE EAST LTD

R26079

PO BOX 23021

INDUSTRIAL AREA NO 6

SHARJAH, UNITED ARAB EMIRATES

Adhesive designated Duct Bond 80-10/80-30.

	Applied to Inorganic Reinforced Cement Board+
Flame spread	0
Smoke developed	0

+ Tested as applied at a coverage rate of 200 sq. ft. per gallon.

Flash point of finished sealant (closed cup) -14° F.

Sealant designated Duct Seal 32-7.

	Applied to Inorganic Reinforced Cement Board+
Flame spread	0
Smoke developed	0

+ Tested as applied in two 2 in. wide strip, OC (Covering 22.2 percent of the exposed test sample area) at a coverage rate of 25 sq. ft. per gallon.

Coatings designated Vapour Barrier 30-8/30-40AF and Lag Coat 30-6/30-10AF..

	Applied to Inorganic Reinforced Cement Board+
Flame spread	10
Smoke developed	45

+ Tested as applied at a coverage rate of 40 sq. ft. per gallon.

Last Updated on 2017-04-14

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".